

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No.F6/DFS/MS/School/SZ/2021/541

Dated: 27/07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Modern Era Convent School running at ground plus two upper floors a building comprised of basement, ground plus two upper floors located at B-1, Block Janakpuri, New Delhi, owned/occupied Modern Era Convent School was issued FSC vide letter no. F.6/DFS/MS/school/2007/3486 dated 16/11/2007. The school building was re- inspected by the officer concerned of this department on dated 19/07/2021 in the presence of Sh. Rajat (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education, Govt. of NCT of Delhi, and that the building (G-2) is fit for occupancy class B 'Educational Building' with effect from 27/07/2021, for a period of three years, subject to conditions printed below.

Issued on 27/07/2021 at New Delhi by

*(Signature)*  
**Principal**  
Modern Era Convent  
Sr. Secondary School  
B-1 Block, Janak Puri,  
New Delhi-110058

*(Signature)*  
**(Sunil Chawdhary)**  
Dy. Chief Fire Officer  
*(Signature)*

To,  
The Principal,  
Modern Era Convent School,  
B-1, Block Janakpuri, New Delhi.

Copy to:-  
Director of Education  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

**MODERN ERA CONVENT**  
*(Signature)*  
**Manager**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.