

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



**DELHI JAL BOARD ; (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085.**



ACWA HAIDER PUR
26/04/24
26/04/24

(ISO Certified 9001:2015)

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water sample collected from DJB Stored Water in the premises of **Modern Era Convent School**, B-1 Block, Janakpuri, New Delhi - 110058 vide challan no. 17 dated 15.04.2024.

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	24.04.2024
2.	Date of Analysis	--	---	---	26.04.2024
3.	Colour	C.U.	5	15	<1 C.U.
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	2.48
6.	p ^H value	--	6.5 to 8.5	N.R.	7.5
7.	Electrical Conductivity	µmhos/cm	---	---	308.0
8.	Total Dissolved Solid	(mg/l)	500	2000	200.2
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil
10.	Total Alkalinity	(mg/l)	200	600	87.0
11.	Total Hardness	(mg/l)	200	600	123.0
12.	Calcium Hardness	(mg/l)	200	600	83.0
13.	Magnesium Hardness	(mg/l)	200	600	40.0
14.	Calcium as Ca	(mg/l)	75	200	33.2
15.	Magnesium as mg	(mg/l)	30	100	9.6
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	2.17
19.	Sulphate (SO ₄)	(mg/l)	200	400	37.38
20.	Chloride (Cl)	(mg/l)	250	1000	10.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.30
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.75
BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37 ^o C	MPN/100 mL	0		0

Remarks: On the basis of above tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

A.C.W.A. (HP- I)

C.W.A. (W&S)-II



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SING VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D- 206

Dated: 26/04/24


HEALTH CERTIFICATE

1. Name of the School Modern Era Convent School
2. School address B-1, Janakpuri, New Delhi-110058
3. No of shifts 01 (Morning) Timing 08:00 AM TO 2.00 PM
4. No of students:- Boys 540 Girls 484 Total 1024
5. No of staff: - Gents 06 Ladies 36 Total 42

Accommodation provide for classroom as under:-


- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue


Principal
Modern Era Convent
Sr. Secondary School
B-1 Block, Janak Puri,
New Delhi-110058

MODERN ERA CONVENT

Manager


Dy. Health Officer
West Zone
Dy Health Officer
West Zone
MCD